

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 30 Jun 2024 to 01 Jul 2024

Water Supply Zone: 402

Water Supply Zone Area: Tetbury and Kingscote

Water Supply Zone Population: 7612

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Antimony Total	1	0	0.07	0.07	0.07		UGSB
Arsenic Total	1	0	0.15	0.15	0.15	10	UGAS
Benzo(a)Pyrene	1	0	0.42	0.42	0.42	10	NG_P_L
Benzobfluoranthene	1	0	0.0007	0	0.0007		UG_P_L
Benzo-Ghi-Perylene	1	0	0.00077	0	0.00077		UG_P_L
Benzo(k)fluoranthene	1	0	0.00099	0	0.00099		UG_P_L
Bromate as BrO3	1	0	0.2	0.2	0.2	10	UGBRO
Bromodichloromethane	1	0	0.68	0.68	0.68		UG_P_L
Cadmium Total	1	0	0.03	0.03	0.03		UGCDL
Chromium Total	1	0	0.29	0.29	0.29		UGCRL
Colony Count after 3 days @22C	1	0	1	1	1		CFU_1ML
Colour	1	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	1	0	1.77	1.77	1.77		UG_P_L
E.Coli Confirmed	1	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	1	0	0	0	0	0	CFU_100ML
Field Free Chlorine	1	0	0.63	0.63	0.63		MG_P_L
Field Total Chlorine	1	0	0.65	0.65	0.65		MG_P_L
First Draw Copper	1	0	22.8	22.8	22.8	2,000	UG_P_L
First Draw Nickel	1	0	1.73	1.73	1.73	20	UGNI
First Draw Pb	1	0	0.24	0.24	0.24	10	UGPB
Hydrogen ion (pH)	1	0	7.62	7.62	7.62		PH
Indeno-123-Cd-Pyrene	1	0	0.00104	0	0.00104		UG_P_L
Nitrate as NO3	1	0	2.13	2.13	2.13	50	MGNO_3
Nitrite as NO2 (consumer tap)	1	0	0.002	0	0.002	0.5	MGNO_2
Nitrogen Formula	1	0	0.043	0.04	0.043		MG_P_L
PAH Total	1	0	0	0	0	0.1	UG_P_L
Selenium Total	1	0	0.32	0.32	0.32	10	UGSE
Sodium	1	0	22	22	22	200	MGNA
Total Coliforms (Indicator)	1	0	0	0	0	0	CFU_100ML

Water Quality Summary Date Range: 30 Jun 2024 to 01 Jul 2024

Water Supply Zone: 402

Water Supply Zone Area: Tetbury and Kingscote

Water Supply Zone Population: 7612

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Total Iron	1	0	5.23	5.23	5.23	200	UGFE
Total Manganese	1	0	0.3	0.3	0.3	50	UGMN
Total Oxidised Nitrogen	1	0	2.13	2.13	2.13		MG_P_L
Total Trihalomethanes	1	0	4.16	4.16	4.16	100	MICROG_L
Tribromomethane	1	0	1.71	1.71	1.71		UG_P_L
Trichloromethane	1	0	0.67	0.67	0.67		UG_P_L
Turbidity (Treated)	1	0	0.33	0.33	0.33	4	NTU