

# PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 30 Jun 2023 to 01 Jul 2024

Treatment Works: Littleton Treated (27410010)

## Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	4	0	0.16	0.16	0.16	3	UG_P_L
2,4-Dichlorophenoxyacetic acid	5	0	0.011	0.01	0.011	0.1	UG_P_L
Benzene	4	0	0.06	0.06	0.06	1	UG_P_L
Boron Total	4	0	49.7	56.58	65	1,000	UG_P_L
Carbetamide	5	0	0.009	0.01	0.013	0.1	UG_P_L
Chloride as Cl	3	0	39.6	46.8	53.4	250	MGCL
Clopyralid	5	0	0.011	0.01	0.011	0.1	UG_P_L
Clostridia Perfringens Confirmed	34	0	0	0	0	0	CFU_100ML
Coliforms Confirmed	122	2	0	0.02	2	0	CFU_100ML
Colony Count after 3 days @22C	122	0	0	0.21	5		CFU_1ML
Conductivity	36	0	427	559.81	685	2,500	US_P_CM
Cyanide Total as CN	4	0	1.2	1.2	1.2	50	UGCNL
E.Coli Confirmed	122	0	0	0	0	0	CFU_100ML
Field Free Chlorine	122	0	0.66	1.11	1.99		MG_P_L
Field Total Chlorine	122	0	0.61	1.2	2		MG_P_L
Flufenacet	5	0	0.008	0.01	0.008	0.1	UG_P_L
Fluoride	4	0	80	125	150	1,500	UG_P_L
Fluroxypyr	5	0	0.008	0.01	0.008	0.1	UG_P_L
Glyphosate	5	0	0.005	0.01	0.005	0.1	UG_P_L
MCPA	5	0	0.006	0.01	0.006	0.1	UG_P_L
MCPP	5	0	0.009	0.01	0.009	0.1	UG_P_L
Mepiquat Chloride	5	0	0.004	0.01	0.008	0.1	MICROG_L
Mercury Total	4	0	0.04	0.05	0.06	1	UGHG
Metaldehyde	5	0	0.006	0.01	0.007	0.1	UG_P_L
Nitrate as NO3	3	0	18.18	20.24	23.1	50	MGNO_3
Nitrite as NO2	3	0	0.002	0	0.003	0.1	MGNO_2
Nitrogen Formula	3	0	0.364	0.41	0.463		MG_P_L
Propyzamide	5	0	0.009	0.01	0.038	0.1	UG_P_L
Prosulfocarb	5	0	0.006	0.01	0.01	0.1	UG_P_L
Quinmerac	5	0	0.006	0.01	0.009	0.1	UG_P_L
Sulphate	4	0	43.7	63.73	78.6	250	MGSO_4

Water Quality Summary Date Range: 30 Jun 2023 to 01 Jul 2024

Treatment Works: Littleton Treated (27410010)

## Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Tebuconazole	5	0	0.005	0.01	0.006	0.1	UG_P_L
Tetrachloroethene	4	0	0.45	0.45	0.45		UG_P_L
Tetrachloromethane	4	0	0.16	0.16	0.16	3	UG_P_L
Total Chloroethenes	4	0	0.85	0.85	0.85	10	MICROG_L
Total Coliforms (Confirmed)	122	2	0	0.02	2	0	CFU_100ML
Total organic Carbon	4	0	1.69	1.73	1.82		MG_P_L
Total Oxidised Nitrogen	3	0	18.18	20.24	23.1		MG_P_L
Total Pesticides	5	0	0	0.01	0.038	0.5	UG_P_L
Tri-allate	5	0	0.006	0.01	0.006	0.1	UG_P_L
Trichloroethene	4	0	0.4	0.4	0.4		UG_P_L
Triclopyr	5	0	0.016	0.02	0.016	0.1	UG_P_L
Turbidity - Indicator	122	0	0.13	0.16	0.33	1	NTU